

2025 WATER QUALITY REPORT FOR City of Hull

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. All of our water is purchased. Purchased water comes from Rock Valley Rural Water District and Lewis and Clark Regional Water. Water quality testing shows the following results:

ROCK VALLEY RURAL WATER

CONTAMINANT	MCL – (MCLG)	TYPE	VALUE & RANGE	DATE SAMPLED	VIOLATION	SOURCE
TTHM (ppb) [Total trihalomethanes]	80(N/A)	LRAA	28.00 (28-28)	09-30-2025	no	By-products of drinking water chlorination
Total Haloacetic Acids (HAA5) (ppb)	60 (N/A)	LRAA	31.00 (31-31)	09-30-2025	no	By-products of drinking water disinfection
Lead (ppb)	AL=15 (0)	90th	2.40 (ND-4)	2025	no	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3(1.3)	90th	0.2505 (0.0068-0.4900)	2025	no	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
950-DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDLG & MRDL = 4.0	RAA	1.6 (0.81-2.81)	03/31/2025	No	Water additive used to control microbes
06-WELLS 1-14, 16-19/PLT 2 LAB SINK						
Nitrate [as N] (ppm)	10 (10)	SGL	2.73	2025	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposit

HULL WATER SUPPLY

CONTAMINANT	MCL- (MCLG)	TYPE	VALUE & RANGE	DATE SAMPLED	VIOLATION	SOURCE
Lead (ppb)	AL=15 (0)	90th	1.80 (ND-8)	2024	no	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3(1.3)	90th	0.1728 (ND-0.2068)	2024	no	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
TTHM (ppb) [Total trihalomethanes]	80 (N/A)	LRAA	24.00 (24-24)	09-30-2025	no	By-products of drinking water chlorination
Total Haloacetic Acids (HAA5) (ppb)	60 (N/A)	LRAA	12.00 (12-12)	09-30-2025	no	By-products of drinking water disinfection
Chlorine (ppm)	MRDLG 4.0	RAA	2.6 (2.09-2.89)	12-31-2025	No	Water additive used to control microbes

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

LEWIS & CLARK REGIONAL WATER

CONTAMINANT	MCLG	MCL	TYPE	VALUE & RANGE	DATE SAMPLED	VIOLATION	SOURCE
Arsenic (ppb)	0	10		1 (1.00-1.00)	03/18/2025	no	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium (ppm)	2	2		0.0102 (0.0102-0.0102)	03/18/2025	no	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Nitrate ppm (as Nitrogen)	10	10		0.3	06/23/2025	no	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

This water supply obtains all of its water from another public water supply. It is a consecutive water supply, where an originating parent supply provides drinking water to one or more downstream supplies.

Original Supply ID	Original Supply Name
IA 8482701	Rock Valley Rural Water District
EPA ID 2288	Lewis and Clark Regional Water System

CONTACT INFORMATION

For questions regarding this information, please contact Brent Kleinwolterink at 712-439-1521 during the following hours: 7:30 a.m. to 4:00 p.m.

Decisions regarding the water system are made at the Hull City Council meetings held on 2nd & 4th Mondays of each month at 5:00 p.m. at the Hull City Council Chambers and are open to the public.